



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Elmira City School District

Project Name: Drinking Water

Mike Dunn
733 Benjamin Street
Elmira, NY 14901

Project / PO Number: N/A
Received: 10/04/2016 10:50
Reported: 11/30/2016 22:40

Case Narrative

The Matrix Spike Duplicate performed on the following sample failed the precision criteria for lead. The accuracy criteria were met by both the Matrix Spike and Matrix Spike Duplicate. This data is indicative of a bias related to sample matrix.

Table with 2 columns: Laboratory ID, Sample Name. Row 1: 16K0707-10, S6K0147-10 (F2)

Analytical Testing Parameters

Table with 2 columns: Client/Lab Sample ID, Sample Type, Collected By, Collection Date, Collection Time. Row 1: KIT 1, S6K0147-01, Grab, DI-Client, 09/29/16, 04:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1442

Analytical Testing Parameters

Table with 2 columns: Client/Lab Sample ID, Sample Type, Collected By, Collection Date, Collection Time. Row 1: KIT 2, S6K0147-02, Grab, DI-Client, 09/29/16, 04:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00338, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1444



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: KIT 4
Lab Sample ID: S6K0147-03
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1445

Analytical Testing Parameters

Client Sample ID: KIT 5
Lab Sample ID: S6K0147-04
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1446

Analytical Testing Parameters

Client Sample ID: KIT 6
Lab Sample ID: S6K0147-05
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1446



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: KIT 7
Lab Sample ID: S6K0147-06
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00343, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1450

Analytical Testing Parameters

Client Sample ID: POT 1
Lab Sample ID: S6K0147-07
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00707, 0.015, 0.00500, mg/L, 11/22/16 0709, 11/22/16 1145

Analytical Testing Parameters

Client Sample ID: KIT LAV
Lab Sample ID: S6K0147-08
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00199, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1451



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: F1
Lab Sample ID: S6K0147-09
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1451

Analytical Testing Parameters

Client Sample ID: F2
Lab Sample ID: S6K0147-10
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1452

Analytical Testing Parameters

Client Sample ID: F3
Lab Sample ID: S6K0147-11
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1454



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: F4
Lab Sample ID: S6K0147-12
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1455

Analytical Testing Parameters

Client Sample ID: F5
Lab Sample ID: S6K0147-13
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1455

Analytical Testing Parameters

Client Sample ID: A 102
Lab Sample ID: S6K0147-14
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00235, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1456



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: A 109 B
Lab Sample ID: S6K0147-15
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1458

Analytical Testing Parameters

Client Sample ID: A 109 F
Lab Sample ID: S6K0147-16
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00105, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1500

Analytical Testing Parameters

Client Sample ID: A110 F2
Lab Sample ID: S6K0147-17
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00229, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1501



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: A 110 B
Lab Sample ID: S6K0147-18
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1501

Analytical Testing Parameters

Client Sample ID: A 110 F
Lab Sample ID: S6K0147-19
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1502

Analytical Testing Parameters

Client Sample ID: A111 L
Lab Sample ID: S6K0147-20
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1503



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: A111 F
Lab Sample ID: S6K0147-21
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1506

Analytical Testing Parameters

Client Sample ID: A111 B
Lab Sample ID: S6K0147-22
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1507

Analytical Testing Parameters

Client Sample ID: A112 B
Lab Sample ID: S6K0147-23
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1508





Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: A112 F
Lab Sample ID: S6K0147-24
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1508

Analytical Testing Parameters

Client Sample ID: B 104 F
Lab Sample ID: S6K0147-25
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00202, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1509

Analytical Testing Parameters

Client Sample ID: B 111
Lab Sample ID: S6K0147-26
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1510



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: C 101
Lab Sample ID: S6K0147-27
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00293, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1510

Analytical Testing Parameters

Client Sample ID: C 106 F
Lab Sample ID: S6K0147-28
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00218, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1511

Analytical Testing Parameters

Client Sample ID: C 106 B
Lab Sample ID: S6K0147-29
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00205, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1512



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: C 107 B
Lab Sample ID: S6K0147-30
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 04:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1512

Analytical Testing Parameters

Client Sample ID: C 107 F
Lab Sample ID: S6K0147-31
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00184, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1515

Analytical Testing Parameters

Client Sample ID: C 108 L1
Lab Sample ID: S6K0147-32
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1515



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: C 108 L2
Lab Sample ID: S6K0147-33
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00130, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1516

Analytical Testing Parameters

Client Sample ID: C 108 B
Lab Sample ID: S6K0147-34
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1517

Analytical Testing Parameters

Client Sample ID: C 110 F
Lab Sample ID: S6K0147-35
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1517



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: C 110 B
Lab Sample ID: S6K0147-36
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1518

Analytical Testing Parameters

Client Sample ID: D 101 B
Lab Sample ID: S6K0147-37
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1519

Analytical Testing Parameters

Client Sample ID: D 101 F
Lab Sample ID: S6K0147-38
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1519



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: D 103 L1
Lab Sample ID: S6K0147-39
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1520

Analytical Testing Parameters

Client Sample ID: D 103 L3
Lab Sample ID: S6K0147-40
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00107, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1521

Analytical Testing Parameters

Client Sample ID: D 103 B
Lab Sample ID: S6K0147-41
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1524



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: D 104 F
Lab Sample ID: S6K0147-42
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1525

Analytical Testing Parameters

Client Sample ID: D 104 B
Lab Sample ID: S6K0147-43
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1525

Analytical Testing Parameters

Client Sample ID: D 126
Lab Sample ID: S6K0147-44
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1526



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: A 204 F
Lab Sample ID: S6K0147-45
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1527

Analytical Testing Parameters

Client Sample ID: A 205 F
Lab Sample ID: S6K0147-46
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1529

Analytical Testing Parameters

Client Sample ID: A 211 F
Lab Sample ID: S6K0147-47
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1531





Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: A 212 F1
Lab Sample ID: S6K0147-48
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1532

Analytical Testing Parameters

Client Sample ID: A 212 F2
Lab Sample ID: S6K0147-49
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1532

Analytical Testing Parameters

Client Sample ID: A 214 F
Lab Sample ID: S6K0147-50
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1533



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: A 215 F
Lab Sample ID: S6K0147-51
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1535

Analytical Testing Parameters

Client Sample ID: B 203 LAV
Lab Sample ID: S6K0147-52
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00141, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1536

Analytical Testing Parameters

Client Sample ID: B 203 F
Lab Sample ID: S6K0147-53
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1536



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: B 204 F1
Lab Sample ID: S6K0147-54
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00371, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1537

Analytical Testing Parameters

Client Sample ID: B 204 F2
Lab Sample ID: S6K0147-55
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00146, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1539

Analytical Testing Parameters

Client Sample ID: B 210 F
Lab Sample ID: S6K0147-56
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1541



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: 106 B
Lab Sample ID: S6K0147-57
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1542

Analytical Testing Parameters

Client Sample ID: 106 F
Lab Sample ID: S6K0147-58
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00125, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1543

Analytical Testing Parameters

Client Sample ID: B 214 F
Lab Sample ID: S6K0147-59
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1543



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: NL 1
Lab Sample ID: S6K0147-60
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1544

Analytical Testing Parameters

Client Sample ID: NE 1
Lab Sample ID: S6K0147-61
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0137, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1547

Analytical Testing Parameters

Client Sample ID: LAV 213
Lab Sample ID: S6K0147-62
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1548



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: LAV 204
Lab Sample ID: S6K0147-63
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1549

Analytical Testing Parameters

Client Sample ID: CAFE L
Lab Sample ID: S6K0147-64
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1549

Analytical Testing Parameters

Client Sample ID: LAV 106
Lab Sample ID: S6K0147-65
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1550



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: Coach LAV
Lab Sample ID: S6K0147-66
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00116, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1551

Analytical Testing Parameters

Client Sample ID: LAV 201
Lab Sample ID: S6K0147-67
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1552

Analytical Testing Parameters

Client Sample ID: LAV 109
Lab Sample ID: S6K0147-68
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00180, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1552



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

Analytical Testing Parameters

Client Sample ID: LAV 105
Lab Sample ID: S6K0147-69
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1553

Analytical Testing Parameters

Client Sample ID: L LAV
Lab Sample ID: S6K0147-70
Sample Type: Grab

Collected By: DI-Client
Collection Date: 09/29/16
Collection Time: 05:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/16/16 2059, 11/18/16 1554

Laboratory

SAY: Microbac Laboratories, Inc., Sayre Division

Definitions

AL: Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, Item, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland
NY Lab ID No: 12006
PA DEP ID: 68-04863

New York State Department of Health
Pennsylvania Department of Environmental Protection





Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S6K0147

**Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

**Go Green:** Contact Renee Lantz to set up email reporting and invoicing options.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Renee Lantz, Project Manager at [renee.lantz@microbac.com](mailto:renee.lantz@microbac.com). You may also contact Michael Fifield, Managing Director at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com) or Robert Crookston, President at [robert.crookston@microbac.com](mailto:robert.crookston@microbac.com).*

**Reviewed and Approved By:**

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield For Renee Lantz  
Project Manager  
11/30/2016 22:40

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

Samples must be returned on ice  
 MNY Workorder #

Client Information		Billing/Invoicing:	
Name: <u>Elmira City Schools</u>	<u>Elmira City Schools</u>	Name: <u>Elmira City Schools</u>	<u>Elmira City Schools</u>
Address: <u>D Wren Elementary</u>	<u>733 Berdemin St</u>	Address: <u>D Wren Elementary</u>	<u>733 Berdemin St</u>
<u>115 Hall St Elmira 14904</u>	<u>Elmira, NY 14901</u>	<u>115 Hall St Elmira 14904</u>	<u>Elmira, NY 14901</u>
Contact: <u>Michael Dwyer</u>	<u>Michael Dwyer</u>	Contact: <u>Michael Dwyer</u>	<u>Michael Dwyer</u>
Phone: <u>607-735-3980</u>	<u>607-735-3980</u>	Phone: <u>607-735-3980</u>	<u>607-735-3980</u>
Project: <u>Lead In D.W.</u>	PO#:	Project: <u>Lead In D.W.</u>	PO#:
Quote ID:	Date Req.:	Quote ID:	Date Req.:
Rush TAT Bus. Days: <u>2-5 5-7 7-10</u>	<u>2-5 5-7 7-10</u>	Rush TAT Bus. Days: <u>2-5 5-7 7-10</u>	<u>2-5 5-7 7-10</u>
Carbon Copy: <u>Yes</u>	<u>dinscanna.ecs@schools.org</u>	Carbon Copy: <u>Yes</u>	<u>dinscanna.ecs@schools.org</u>
Email Results: <u>Yes</u>	<u>industry@elmira-cityschools.com</u>	Email Results: <u>Yes</u>	<u>industry@elmira-cityschools.com</u>
Fax Results: <u>Yes</u>		Fax Results: <u>Yes</u>	

Sample Information			Matrix	Number of Containers for Analysis Requested		Comments/Field Data
Description/Location	Date	Time	Type	1	2	
Kit 1	9-29-16	0430	Grab	1		
Kit 2	9-29-16	0431	Grab	1		
Kit 4	9-29-16	0432	Grab	1		
Kit 5	9-29-16	0433	Grab	1		
Kit 6	9-29-16	0434	Grab	1		
Kit 7	9-29-16	0435	Grab	1		
Pot 1	9-29-16	0436	Grab	1		
Kit LAV	9-29-16	0437	Grab	1		

Signature		Date/Time	Comments
<u>Dominic Insogna</u>		<u>9-29-16 0900</u>	
<u>deneelantelm</u>		<u>10/4/16 1050</u>	
Print Name and Company			
Signature			
Print Name and Company			

S 6 K 0 1 4 7  
 Elmira City School District/Maintenance

Microbac Laboratories (MND) may be unable to perform portions of the requested analysis if the samples are not received in a timely manner. By signing this document you are certifying that you have read and understood the terms and conditions of the agreement with this laboratory.

3821 Buck Drive  
 Cortland NY 13045  
 Phone: (607)753-3403 Fax: (607)753-3415  
 NY #10795, EPA #NY00935

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

MNY Workorder #

Client Information		Billing/Invoice:	
Name: <i>Elmira City Schools</i>	Name: <i>Elmira City Schools</i>		
Address: <i>Dwight Elementary 733 Benjamin St</i>	Address: <i>733 Benjamin St</i>		
<i>115 Hall St Elmira 14901</i>	<i>Elmira, NY 14901</i>		
Contact: <i>Michael Duan</i>	Contact: <i>Michael Duan</i>		
Phone: <i>607-735-3980</i>	Phone: <i>607-735-3980</i>		
Project: <i>Lead In D.W.</i>	PO#:		
Quote ID:	Date Req:		
Rush TAT Bus. Days: <input checked="" type="checkbox"/> 2-5 <input checked="" type="checkbox"/> 5-7 7-10	Date Req:		
Carbon Copy: <input checked="" type="checkbox"/> <i>disagna.ecstboxes.org</i>			
Email Results: <input checked="" type="checkbox"/> <i>industry@elmira-cityschools.com</i>			
Fax Results: <input checked="" type="checkbox"/>			

Sample Information		Matrix		Number of Containers for Analysis Requested	Date/Time	Comments
Description/Location	Date	Time	Initial			
F1	9-29-16	0438	DI	1		
F2	9-29-16	0439	DI	1		
F3	9-29-16	0440	DI	1		
F4	9-29-16	0441	DI	1		
F5	9-29-16	0442	DI	1		
A102	9-29-16	0443	DI	1		
A109B	9-29-16	0444	DI	1		
A109F	9-29-16	0445	DI	1		

Print Name and Company		Signature	
<i>Dominic Kasoga, ECSD</i>		<i>Dom Jof</i>	
Date/Time		Date/Time	
<i>9-29-16 0900</i>		<i>10/4/16 050</i>	
Received: <i>Daniel M. ...</i>		Received:	
Received:		Received:	



Elmira City School District/Maintenance

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on ice

3821 Buck Drive  
 Cortland NY 13045  
 Phone: (607)753-3403 Fax: (607)753-3415  
 NY #10795, EPA #NY00935

MNY Workorder #

Client Information		Billing/Invoicing				Analytix Requested		Receiving Info (Lab Use Only)	
Name: <u>Elmira City Schools</u> Address: <u>Dixen Elementary</u> <u>115 Falls Elmira 14904</u> Contact: <u>Michael Dunn</u> Phone: <u>607-735-3980</u> Project: <u>Lead In D.W.</u> Quote ID: Rush TAT Bus. Days: <input type="checkbox"/> 2-5 <input type="checkbox"/> 5-7 <input type="checkbox"/> 7-10 Carbon Copy: <input checked="" type="checkbox"/> <u>dinscanna@gstboxes.org</u> Email Results: <input checked="" type="checkbox"/> <u>mdunn@elmira-cityschools.com</u> Fax Results: <input type="checkbox"/> Yes		<u>Elmira City Schools</u> <u>733 Benjamin St</u> <u>Elmira, NY 14901</u> <u>Michael Dunn</u> <u>607-735-3980</u> PO#:				Lead In D.W.		Icer: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> Coolers: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> Sample Temp: _____ Cooler Seal: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> Pickup: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> Dropoff: C <input type="checkbox"/> W <input checked="" type="checkbox"/> Accepted?: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data					
Description/Location	Date	Time	Initial	Matrix Type					
B104F	9-29-16	0454	DI	Grab	1				
B111	9-29-16	0455	DI	Grab	1				
C101	9-29-16	0456	DI	Grab	1				
C106F	9-29-16	0457	DI	Grab	1				
C106B	9-29-16	0458	DI	Grab	1				
C107B	9-29-16	0459	DI	Grab	1				
C107F	9-29-16	0500	DI	Grab	1				
C108L1	9-29-16	0501	DI	Grab	1				
Sampled: <u>Dominic Insogna, ECSD</u> Received: <u>Kenee Lantz, mu</u> Received: Received:		Signature: <u>[Signature]</u> Date/Time: <u>9-29-16 0900</u> <u>10/4/16 1050</u>		Comments:					



Elmira City School District/Maintenance

Microbac Laboratories (MNY) may be unable to perform the requested testing that you have been informed by MNY of the intent to subcontract and an attempt to subcontract the analysis on-site at the laboratory. By signing this document you are consenting that you have been informed by MNY of the intent to subcontract and an attempt to subcontract the analysis on-site at the laboratory.

# Microbac Laboratories, Inc. Samples must be returned on ice CHAIN OF CUSTODY

3821 Buck Drive  
Cortland NY 13045  
Phone: (607) 753-3403 Fax: (607) 753-3415  
NY #10795, EPA #NY00935

MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)			
Name:	Elmira City Schools		Name:	Elmira City Schools		Ice:	YES	NO	Container Material	Accepted?	YES	NO
Address:	Dixen Elementary 733 Bernein St 115 Ball St Elmira 14904		Address:	733 Bernein St Elmira, NY 14901		Coolers:	YES	NO	Container Size (in MI)	Dropoff:	C	W
Contact:	Michael Dum		Contact:	Michael Dum		Sample Temp:				Prefeructive		
Phone:	607-735-3980		Phone:	607-735-3980		Cooler Seal:	YES	NO				
Project:	Lead In D.W.		Project:	Lead In D.W.		Pickup:	YES	NO				
Quote ID:			Quote ID:									
Rush TAT Bus. Days:	2-5	5-7	Date Req.:									
Carbon Copy:	Yes		Carbon Copy:	disonana.estboxes.org								
Email Results:	Yes		Email Results:	industry@elmira-city-schools.com								
Fax Results:	Yes		Fax Results:									
Sample Information				Number of Containers for Analysis Requested				Comments/Field Data				
Description/Location	Date	Time	Initial	Matrix Type								
1 C108L2	9-29-16	0502	DI	Grab	1							
2 C108B	9-29-16	0503	DI	Grab	1							
3 C110F	9-29-16	0504	DI	Grab	1							
4 C110B	9-29-16	0505	DI	Grab	1							
5 D101B	9-29-16	0506	DI	Grab	1							
6 D101F	9-29-16	0507	DI	Grab	1							
7 D103L1	9-29-16	0508	DI	Grab	1							
8 D103L2	9-29-16	0509	DI	Grab	1							
Print Name and Company				Signature				Date/Time				
Sampled: Dominic Insogna, ECSD				[Signature]				9-29-16 0900				
Received: Renee Lantieri				[Signature]				10/4/16 1050				
Received:												
Received:												



Elmira City School District/Maintenance

Microbac Laboratories (MNY) may be unable to perform the portion of the requested testing if the samples are not received in a timely manner. By signing this document you are certifying that you are in agreement with this action.

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

# Microbac Laboratories, Inc. Samples must be returned on ice CHAIN OF CUSTODY

MNY Workorder #

Client Information		Billing/Invoice:	
Name: <u>Elmira City Schools</u>	<u>Elmiracityschools</u>		
Address: <u>D Wren Elementary</u>	<u>733 Benjamin St</u>		
<u>115 6th St Elmira</u>	<u>Elmira, NY 14901</u>		
Contact: <u>Michael Durr</u>	<u>Michael Durr</u>		
Phone: <u>607-735-3980</u>	<u>607-735-3980</u>		
Project: <u>Lead In D.W.</u>	PO#:		
Quote ID:	Date Req:		
Rush TAT Bus. Days: <u>3 2-5 5-7 7-10</u>	Carbon Copy: <input checked="" type="checkbox"/> <u>dinscova@estboxes.org</u>		
Email Results: <input checked="" type="checkbox"/> <u>indur@elmira-cityschools.com</u>	Fax Results: <input checked="" type="checkbox"/> <u>Yes</u>		



Elmira City School District/Maintenance

Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Analysis Requested		Receiving Info (Lab Use Only)
						Accepted?	Container Material	
1 D103B	9-29-16	0510	DI	Grab	1	<input checked="" type="checkbox"/>	Plastic	Ice: YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/> Coolers: YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/> Sample Temp: <u>—</u> Cooler Seal: YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/> Pickup: YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/> Dropoff: C <input checked="" type="checkbox"/> W <input checked="" type="checkbox"/> Accepted? <input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/> Container Material: <u>Plastic</u> Container Size (In MI): <u>250</u> Preservative: <u>None</u>
2 D104F	9-29-16	0511	DI	Grab	1	<input checked="" type="checkbox"/>		
3 D104B	9-29-16	0512	DI	Grab	1	<input checked="" type="checkbox"/>		
4 D126	9-29-16	0513	DI	Grab	1	<input checked="" type="checkbox"/>		
5 A204F	9-29-16	0514	DI	Grab	1	<input checked="" type="checkbox"/>		
6 A205F	9-29-16	0515	DI	Grab	1	<input checked="" type="checkbox"/>		
7 A211F	9-29-16	0516	DI	Grab	1	<input checked="" type="checkbox"/>		
8 A212F1	9-29-16	0517	DI	Grab	1	<input checked="" type="checkbox"/>		

Sampled: <u>Dominic Insogna</u>	Signature: <u>[Signature]</u>	Date/Time: <u>9-29-16 0900</u>	Comments
Received: <u>Kenec Lantieri</u>	Signature: <u>[Signature]</u>	Date/Time: <u>10/10/16-1050</u>	
Received:	Signature:	Date/Time:	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing if the samples are not received in a timely manner. By signing this document you are certifying that you have been informed by MNY of the intent to subcontract and an agreement with this action.

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

# Microbac Laboratories, Inc. Samples must be returned on ice CHAIN OF CUSTODY

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Elmira City Schools	Elmira City Schools	
Address:	Dixey Elementary	733 Benjamin St	
	1115 Hall St	Elmira, NY 14901	
Contact:	Michael Dum	607-735-3980	
Phone:	607-735-3980		
Project:	Lead In D.W.		
Quote ID:		PO#:	
Run/TAT Bus. Days:	2-5 5-7 7-10	Date Recd:	
Carbon Copy:	<input checked="" type="checkbox"/> dms@elmira-cityschools.org		
Email Results:	<input checked="" type="checkbox"/> industry@elmira-cityschools.com		
Fax Results:	<input checked="" type="checkbox"/>		

Sample #	Description/Location	Sample Information			Matrix Type	Number of Containers for Analysis Requested	Date/Time	Signature	Comments
		Date	Time	Initial					
1	A212Fa	9-29-16	0518	DI	Grab	1			
2	A214F	9-29-16	0519	DI	Grab	1			
3	A215F	9-29-16	0520	DI	Grab	1			
4	B203LAV	9-29-16	0521	DI	Grab	1			
5	B203F	9-29-16	0522	DI	Grab	1			
6	B204F1	9-29-16	0523	DI	Grab	1			
7	B204F2	9-29-16	0524	DI	Grab	1			
8	B210F	9-29-16	0525	DI	Grab	1			

Sample #	Dominic Insoona, ELSD	Signature	Dominic Insoona	Date/Time	9-29-16 0900
Received:	Kenee Lantieri	Signature	Kenee Lantieri	Date/Time	10/16/16 1050
Received:		Signature		Date/Time	

Barcode: S 6 K 0 1 4 7  
 Elmira City School District/Maintenance

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY009935

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Elmira City Schools	Elmira City Schools	
Address:	Dixen Elementary	735 Benjamin St	
	1115 Falls Elmira	14904 Elmira, NY 14901	
Contact:	Michael Dum	Michael Dum	
Phone:	607-735-3980	607-735-3980	
Project:	Lead In D.W.		
Quote ID:		PO #:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Carbon Copy:	<input checked="" type="checkbox"/> Yes	dinsogna.egstboxes.org	
Email Results:	<input checked="" type="checkbox"/> Yes	indurme@elmira-cityschools.com	
Fax Results:	Yes		

Number of Containers for Analysis Requested	Matrix Type	Sample Information			Date/Time	Signature	Comments
		Description/Location	Date	Time			
1	Grab	1066B	9-29-16	0526	DI		
1	Grab	1066F	9-29-16	0527	DI		
1	Grab	B214F	9-29-16	0528	DI		
1	Grab	77L1	9-29-16	0529	DI		
1	Grab	77E1	9-29-16	0530	DI		
1	Grab	LAV213	9-29-16	0531	DI		
1	Grab	LAV204	9-29-16	0532	DI		
1	Grab	CAFEK	9-29-16	0533	DI		
Sampled: Dominic Masogna, ECSD Received: Terese Lantry, ml Received:							9-29-16 0900 10/10/16 1050



Elmira City School District/Maintenance

Microbac Laboratories (MNY) may be unable to perform portions of the requested analysis if the samples are not properly labeled and sealed. By signing this document you are certifying that you have been informed by MNY of the intent to submit and are in agreement with this action.



3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY009935

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Elmira City Schools	Elmira City Schools	
Address:	Dwight Elementary	733 Berdemin St	
	1115 Hall St	Elmira, NY 14901	
Contact:	Michael Dunn	Michael Dunn	
Phone:	607-735-3980	607-735-3980	
Project:	Lead In D.W.		
Quote ID:		PO#:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req:	
Carbon Copy:	<input checked="" type="checkbox"/> Yes	diosciana@qstboxes.org	
Email Results:	<input checked="" type="checkbox"/> Yes	industry@elmira-cityschools.com	
Fax Results:	Yes		

Sample Information	Sample Information			Matrix Type	Number of Containers for Analysis Requested	Analysis Requested	Receiving Info (Lab Use Only)
	Description/Location	Date	Time				
1	LAV106	9-29-16	0534	DI	1		Ice: YES (NO) Cooler: YES (NO) Sample Temp: YES (NO) Cooler Seal: YES (NO) Pickup: YES (NO) Dropoff: C W Acceptad? YES (NO) Container Material Container Size(In MI) Preservative
2	Coach LAV	9-29-16	0535	DI	1		
3	LAV201	9-29-16	0536	DI	1		
4	LAV109	9-29-16	0537	DI	1		
5	LAV105	9-29-16	0538	DI	1		
6	L LAV	9-29-16	0539	DI	1		
7							
8							

Signature	Date/Time	Comments
[Redacted Signature]	9-29-16 0900	
	10/4/16 1050	
Print Name and Company		
Signature		
Print Name and Company		



Elmira City School District/Maintenance

Microbac Laboratories (MNY) may be unable to perform portion of the requested testing if the case you will subcontract the analysis to another accredited laboratory. By signing this document you are agreeing that you are testing that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Elmira City Schools	Elmira City Schools	
Address:	Dwen Elementary 115 Falls St, Elmira 14901	733 Benjamin St Elmira, NY 14901	
Contact:	Michael Dunn	Michael Dunn	
Phone:	607-735-3980	607-735-3980	
Project:	Lead In D.W.		
Quote ID:		PO#:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Carbon Copy:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	dinsana.eastboxes.org	
Email Results:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	mdunne@elmira-cityschools.com	
Fax Results:	Yes		
Sample Information			
Description/Location	Date	Time	Initial
A110F2	9-29-16	0446	DI
A110B	9-29-16	0447	DI
A110F	9-29-16	0448	DI
A111L	9-29-16	0449	DI
A111F	9-29-16	0450	DI
A111B	9-29-16	0451	DI
A112B	9-29-16	0452	DI
A112F	9-29-16	0453	DI

Sample #	Description/Location	Date	Time	Initial	Matrix	Type	Analysis Requested		Number of Containers for Analysis Requested	Comments/Field Data
							Ice	CO2		
1	A110F2	9-29-16	0446	DI	Plastic	Grab			1	
2	A110B	9-29-16	0447	DI	Plastic	Grab			1	
3	A110F	9-29-16	0448	DI	Plastic	Grab			1	
4	A111L	9-29-16	0449	DI	Plastic	Grab			1	
5	A111F	9-29-16	0450	DI	Plastic	Grab			1	
6	A111B	9-29-16	0451	DI	Plastic	Grab			1	
7	A112B	9-29-16	0452	DI	Plastic	Grab			1	
8	A112F	9-29-16	0453	DI	Plastic	Grab			1	

Signature	Date/Time	Comments
Dominic Insogna, ECSD	9/29/16 0900	
Kenee Lantz, MNY	10/16/16 1050	
Received:		
Received:		
Received:		



Elmira City School District/Maintenance