



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K1085

Elmira City School District

Project Name: Hendy Lead In DW

Mike Dunn
733 Benjamin Street
Elmira, NY 14901

Project / PO Number: N/A
Received: 11/22/2016
Reported: 11/29/2016

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (B104 F1-1, Drinking Water, J6K1085-01, Collected By: DI-Client, Collection Date: 11/22/2016 4:30)

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: Method (200.8- ICP-MS), Result (<0.001), Limit(s) (0.015 AL), RL (0.001), Units (mg/L), Note, Prepared (11/28/16 1012), Analyzed (11/28/16 1218)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (B104 F1-2, Drinking Water, J6K1085-02, Collected By: DI-Client, Collection Date: 11/22/2016 4:31)

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: Method (200.8- ICP-MS), Result (<0.001), Limit(s) (0.015 AL), RL (0.001), Units (mg/L), Note, Prepared (11/28/16 1012), Analyzed (11/28/16 1220)

Laboratory NY: Microbac Laboratories, Inc., New York Division

Definitions AL: Action Level RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. Dayville (NY 11549)
NY Lab ID No: 11549

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K1085

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Reviewed and Approved By:

A handwritten signature in black ink that reads "Renee Lantz".

Renee Lantz
Project Manager
renee.lantz@microbac.com
11/29/2016 20:11

