



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6L1352

Elmira City School District

Project Name: Riverside School

Mike Dunn
733 Benjamin Street
Elmira, NY 14901

Project / PO Number: N/A
Received: 12/23/2016 09:00
Reported: 01/07/2017 22:15

Analytical Testing Parameters

Client Sample ID: K 4- 1
Lab Sample ID: J6L1352-01
Sample Type:

Collected By: DI-Client
Collection Date: 12/23/16
Collection Time: 07:00

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.004	0.015	0.001	mg/L		12/30/16 0958	01/04/17 2101

Analytical Testing Parameters

Client Sample ID: K 4- 2
Lab Sample ID: J6L1352-02
Sample Type:

Collected By: DI-Client
Collection Date: 12/23/16
Collection Time: 07:01

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0028	0.015	0.001	mg/L		12/30/16 0958	01/04/17 2153

Analytical Testing Parameters

Client Sample ID: 204 F1-1
Lab Sample ID: J6L1352-03
Sample Type: Grab

Collected By: DI-Client
Collection Date: 12/23/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0092	0.015	0.001	mg/L		12/30/16 1018	01/04/17 2112



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6L1352

Analytical Testing Parameters

Client Sample ID: 204 F1-2
Lab Sample ID: J6L1352-04
Sample Type: Grab

Collected By: DI-Client
Collection Date: 12/23/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0047, 0.015, 0.001, mg/L, 12/30/16 1018, 01/04/17 2116

Analytical Testing Parameters

Client Sample ID: GLAV3-1
Lab Sample ID: J6L1352-05
Sample Type: Grab

Collected By: DI-Client
Collection Date: 12/23/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/30/16 1018, 01/04/17 2119

Analytical Testing Parameters

Client Sample ID: GLAV3-2
Lab Sample ID: J6L1352-06
Sample Type: Grab

Collected By: DI-Client
Collection Date: 12/23/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/30/16 1018, 01/04/17 2123

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6L1352

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc. Dayville (NY 11549)
NY Lab ID No: 11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Renee Lantz
Project Manager
01/07/2017 22:15

Go Green: Contact Renee Lantz to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Renee Lantz, Project Manager at renee.lantz@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY
 MNY Workorder #

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY009935

Client Information		Billing/Invoice:	
Name: <u>Elmira City Schools</u>	<u>Elmira City Schools</u>		
Address: <u>Riverside School</u>	<u>733 Benjamin St</u>		
<u>409 Riverside Ave, Elmira, NY 14904</u>	<u>Elmira, NY 14904</u>		
Contact: <u>Michael Dunn</u>	<u>Michael Dunn</u>		
Phone: <u>607-735-3980</u>	<u>607-735-3980</u>		
Project:	PO#:		
Quote ID:	Date Req.:		
Rush TAT Bus. Days: <input checked="" type="checkbox"/> 2-5 <input type="checkbox"/> 5-7 <input type="checkbox"/> 7-10			
Carbon Copy: <input checked="" type="checkbox"/> Yes	<u>dinsogna@astbores.org</u>		
Email Results: <input checked="" type="checkbox"/> Yes	<u>mdunnee@elmira-city-schools.com</u>		
Fax Results: <input type="checkbox"/> Yes			

Sample Information			Matrix
Description/Location	Date	Time	Type
1 K4-1	12.23.16	0700	Grab
2 K4-2	12.23.16	0701	30Sec Flush
3 204-F1-1	12.23.16	0710	Grab
4 204-F1-2	12.23.16	0711	30Sec Flush
5 GLAV3-1	12.23.16	0720	Grab
6 GLAV3-2	12.23.16	0721	30Sec Flush
7			
8			

Receiving Info (Lab Use Only)	
Ice:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Cooler:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Sample Temp:	---
Cooler seals:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Dropoff:	C <input type="checkbox"/> W <input type="checkbox"/>
Accepted?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

Analysis Requested		Number of Containers for Analysis Requested		Comments
Lead In D. W.	200.8			
Container Material				
Container Size (in)				
Preservative				
Comment				

Signature	Date/Time	Comments
<u>Dominic Insogna</u>	<u>Dec 23, 2016</u>	
<u>Breanna Tantz</u>	<u>12/23/16</u>	<u>9:00 a-3 day RUSN</u>

J 6 L 1 3 5 2
 Elmira City School District/Maintenance